



**Request for Proposal – Informal Proposal Form**  
**Public Projects (over \$20,000 - \$60,000)**  
**Non-Public Projects (over \$20,000 - \$200,000)**

<b>Project Title:</b>	Lift Station 3 Generator Replacement	<b>Agency Representative:</b>	David Lawrence, P.E., General Manager
<b>Date Issued:</b>	March 30, 2021	<b>Telephone:</b>	909-584-4521
<b>Question Deadline:</b>	April 12, 2021 2:00 p.m.	<b>E-mail:</b>	dlawrence@bbarwa.org
<b>Closing Deadline:</b>	April 19, 2021 2:00 p.m.	<b>Pre-Bid Meeting:</b>	April 9, 2021 at 10:00 a.m.

**SUBMISSION INSTRUCTIONS**

Written proposals shall be submitted using the delivery methods listed below. Proposals must be received by the Agency Representative by the Closing Deadline. Vendors assume the risk of the delivery method selected.

**Late responses will be rejected.**

**Emailed Responses Allowed:** Proposals shall be emailed directly to the Agency Representative.

**PROPOSER INSTRUCTIONS**

1. Contact the Agency Representative as soon as possible with any questions related to the solicitation. A solicitation addendum will be issued if changes are made to this solicitation.
2. The Agency Representative must receive the response by the closing deadline. Late responses will be rejected.
3. The vendor assumes the risk of the response delivery method selected. Contact the Agency Representative to confirm receipt.
4. Sales tax must be included.
5. Prices must be delivered prices (F.O.B. Destination). The successful vendor must pay all transportation and handling charges and file any claims with the carrier for breakage or other losses.
6. Prices must be based upon the specified unit of measure. In the event of mathematic differences between the unit price and extended total price, the unit price will prevail.
7. Responses that do not meet specifications and solicitation requirements will be rejected.
8. Contact Agency Representative to receive a proposal summary.
9. Insurance with BBARWA listed as additional insured will be required. Contact the Agency Representative for insurance requirements, if needed.
10. Contractors will be required to be registered with the DIR.
11. This is a prevailing wage project.
12. Payment and Performance Bonds will be required for this project.
13. Permitting will be the responsibility of BBARWA.
14. Appropriate contractor’s licensing is required.

**Request for Proposal – Informal Proposal  
Proposal Sheet**

**Title:** Lift Station 3 Generator Replacement

**Detailed Specifications:**

Purchase and installation:

- I. MTU 4R0113 DS125, 125KW/156KVA, 277/480V, 3 Phase, Diesel Genset indoors, IBC startup Per NFPA 110 with diesel particulate filter critical grade, or approved equal
  - II. Double wall Fuel tank - 275 Gal PRYCO. (dimensions to be confirmed by contractor before purchase)
  - III. All piping and materials needed for plumbing to the new engine.
  - IV. All piping and materials for tank vents. (This will include coring through block wall and plumbing vent tubes out of building. All penetrations should be properly sealed.)
  - V. Installation of Pryco Fuel station on outside NW wall of lift station. (PRYCO Model #230-22 Serial #77139/230-22/1) Provided by agency.
  - VI. All piping required for plumbing of provided fuel station to fuel tank.
  - VII. Control wire conduit for fuel station. (This will include coring through block wall. All penetrations should be properly sealed.)
- Provide control circuit power to fuel tank and remote fuel station.
  - Provide new radiator shroud.
  - Reinstall power louver actuator.
  - Install push button E-Stop at exit door.

Removal

- Remove existing 150 Gal. fuel tank. Deliver to 121 Palomino dr. Disconnect and dispose of any existing plumbing.
- Remove and dispose of existing radiator shroud.

Remove power louver actuator. (This actuator needs to be removed but will be reinstalled with the new radiator fan shroud.)

3- copies of Operations and Maintenance Manuals

NOTES:

1. Standard Two (2) Year / 3,000 Hour Basic Standby (3D), Limited Warranty.
2. Possible addition of load Bank to engine for diesel particulate filter. (If diesel particulate filter is required then a permanent load bank is required for proper operation.)

<b>Time for Completion: 120 calendar days</b>					
<b>Delivery (F.O.B. Destination) Address:</b> Big Bear Area Regional Wastewater Agency 122 Palomino Drive, Big Bear City, Ca 92314					
<b>Billing Address:</b> Big Bear Area Regional Wastewater Agency P.O. Box 517, Big Bear City, Ca 92314					
RESPONSE					
Item No.	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	1	LS	Mobilization and contract processing costs	\$	\$
2	1	LS	Site prep for installation of new generator (removal, transport and disposal as needed)	\$	\$
3	1	Each	Purchase of generator and related equipment	\$	\$
4	1	LS	Installation of new generator	\$	\$
5	1	LS	Startup and Operations and Maintenance Manuals	\$	\$
6	1	LS	Removal of existing generator and delivery to treatment plant	\$	\$
<b>Award will be made: All</b>				<b>GRAND TOTAL</b>	\$
<b>Can your firm meet the time for completion requirements?      (Circle One) YES    NO</b>					
<b>Vendor Delivery Date (After Receipt of Order):</b>					
<b>Vendor Name:</b>					
<b>Address:</b>					
<b>City:</b>		<b>State:</b>		<b>Zip Code:</b>	
<b>Contact Person:</b>			<b>Title:</b>		
<b>Telephone:</b>			<b>Email:</b>		
<b>DIR #</b>					
<b>Authorized Signature:</b>				<b>Date:</b>	