

Addendum #2

Project: Lift Station 3 Generator Replacement
From: David Lawrence, P.E., General Manager
Date: April 14, 2021

Questions and Answers

1. What are the restrictions for the work in the area?

There is a lock box for access and the working hours are 8 a.m. to 3 p.m.

2. How often do the pumps at the station run?

Pumps run every 5 minutes.

3. Will BBARWA drain the fluids from the auxiliary fuel tank and the generator engine?

No. The contractor will be responsible for draining and disposal of the fluids from the auxiliary fuel tank and generator engine. The contractor shall provide documentation on the disposal vendor/location.

Clarifications and Additions

None this Addendum.

Plan Revisions

None this Addendum.

Acknowledgment in Receipt of Addendum

Firm Name: _____

By (Printed): _____

By: (Signature): _____

Title: _____

Note: A signed acknowledgment in receipt of this addendum MUST be included with your bid proposal.