

## Addendum #3

**Project:** Lift Station 3 Generator Replacement  
**From:** David Lawrence, P.E., General Manager  
**Date:** April 14, 2021

### Questions and Answers

1. Is a DPF and load bank required?

DPF is not anticipated since there does not appear to be any sensitive receptors within 50 meters, or K-12 schools within 100 meters. The facility is not classified as a federal major polluter with a Title V permit.

2. Please clarify if a level 1 enclosure is required or the base model with an enclosure as a level 0.

The generator is inside a building and no enclosure is needed. This is an Open-Air Unit (OPU).

3. If BBARWA is providing the SCAQMD permit, can you confirm if a PM filter is required?

BBARWA will be responsible for permitting. The contractor will need to provide the generator serial number and part numbers before it can be determined if a PM filter is needed. This information is needed for the permit process.

### Clarifications and Additions

None this Addendum.

### Plan Revisions

None this Addendum.

### Acknowledgment in Receipt of Addendum

Firm Name: \_\_\_\_\_

By (Printed): \_\_\_\_\_

By: (Signature): \_\_\_\_\_

Title: \_\_\_\_\_

**Note: A signed acknowledgment in receipt of this addendum MUST be included with your bid proposal.**