

## **Addendum #3**

**Project:** Headworks Grit System Rehabilitation Project  
**From:** David Lawrence, P.E., General Manager  
**Date:** November 15, 2021

### **Questions and Answers**

None this Addendum.

### **Clarifications and Additions**

To clarify the Addendum #2 Item 4 response, the dimensions provided in that response were for the existing SS Angle Grate Supports (i.e., grate seats) along the Headworks channels, which are approximately 1-inch deep (as shown on Sheet S-07, Details 7, 8 and 9) and 1-1/8 inch wide. Per note on drawings, Contractor shall field verify dimensions prior to design of grating system.

The dimensions of the new SS Angles to support the new FRP Covered Grating system are included in Details 4, 7, 8, and 9 on Sheet S-07.

### **Plan Revisions**

None this Addendum.

### **Acknowledgment in Receipt of Addendum #3**

Firm Name: \_\_\_\_\_

By (Printed): \_\_\_\_\_

By: (Signature): \_\_\_\_\_

Title: \_\_\_\_\_

**Note: A signed acknowledgment in receipt of this addendum MUST be included with your bid proposal.**